

Water Cooled Ultra Low Freezer Performance and Energy Use

Sanyo VIP Series Model MDF U76VC

Allen Doyle, MS
Sustainability Manager
Office of Environmental Stewardship and Sustainability
October, 2011

Product Website: <http://us.sanyo.com/Biomedical-Preservation-Ultra-Low-Temperature-Freezers-Upright/MDF-U76VC-26-cu-ft-VIP-Series-86-deg-C-Ultra-Low-Temperature-Freezer>

Disclaimer

NEITHER UC DAVIS, OR ANY OF ITS EMPLOYEES MAKES ANY WARRANTY, EXPRESSED OR IMPLIED, OR ASSUMES ANY LEGAL LIABILITY OF RESPONSIBILITY FOR THE ACCURACY, COMPLETENESS, OR USEFULNESS OF ANY DATA, INFORMATION, METHOD, PRODUCT OR PROCESS DISCLOSES IN THIS DOCUMENT, OR REPRESENTS THAT ITS USE WILL NOT INFRINGE ANY PRIVATELY-OWNED RIGHTS, INCLUDING BUT NOT LIMITED TO, PATENTS, TRADEMARKS, OR COPYRIGHTS.

Acknowledgments

UC Davis acknowledges the support provided by the manufacturers of this equipment who loaned, shipped and advised us on correct operation and testing methods.

UC Davis recognizes the commitment of the participating establishments to increasing the energy efficiency of their facilities and eagerness to support conservation initiatives. The enthusiasm of the facility staff to accommodate our on-site visits and needs was appreciated.

This especially includes the School of Veterinary Medicine, and staff in the Multi-Purpose Teaching facility. The staff of this school has been outstanding in its help and support with providing space and access to valuable laboratory space.

UC Davis Students played an integral role in collecting data sets, moving and unpacking freezers, assembling and calibrating thermocouples. Any errors in reporting are not to be attributed to their work as it was reviewed and supervised by career staff.

Use of UC Davis Test Results and Other Related Information

- University of California, Davis (UC Davis) does not endorse particular products or services from any specific manufacturer or service provider.
- UC Davis is committed to testing laboratory equipment using the customary and standard procedures as recommended by scientists, manufacturers, and will report levels of accuracy and precision when quantified.
- UC Davis does not, in any way, endorse any of the equipment tested on campus.
- UC Davis test results are made available to the general public through the internet and occasional technical research reports and publications and are protected under U.S. and international copyright laws.
- In the event that UC Davis data are to be reported, quoted, or referred to in any way in publications, papers, brochures, advertising, or any other publicly available documents, the rules of copyright must be strictly followed, including written permission from UC Davis *in advance* and proper attribution to UC Davis and the office of Environmental Stewardship and Sustainability. In any such publication, sufficient text must be excerpted or quoted so as to give full and fair representation of findings as reported in the original documentation from UC Davis.

Legal Notice

Reference to specific products or manufacturers is not an endorsement of that product or manufacturer by UC Davis.

Gratitude

Thanks are deserved for people who made this happen at UC Davis. Without their assistance these measurements could not have been made. Any oversights are the responsibility of the author.

Julie Peri, '12
Ziming Li '12
Teresa Souder Vet Medicine
Shawn Rasmussen Vet Medicine
Bill Starr DCM

John Sorenson	DCM
Sally Ivory	Genome Center
Dean Lavelle	Genome Center
Peter Klavins	Physics
Logan Hines	Biology
Mick Pretty	Facilities Management

At Sanyo Joe LaPorte provides stimulating and direct feedback about measurements and stability, and Kurt Kolhede from Lab Equipment Company was helpful with installation, performance review, and product support.

Introduction

The energy intensity of laboratories has come into focus over recent years, and Labs21 has provided a website to publish this data. As well, building designers are looking for new ways to reduce building plug load and cooling from reject heat. The energy consumption of water cooled freezers is lower than air cooled units, and reject heat is shed into process cooling loops.

During September, 2011 staff and students from the office of Environmental Stewardship and Sustainability tested three water cooled, ultra low freezers (ULF, Tables 1 and 2). The manufacturers kindly shipped, helped install the freezers and advised this project. Without their enthusiastic participation it could not have occurred and we are very grateful. The results from the Sanyo freezer testing are presented here.

Distributor	Sanyo
Manufacturer	Sanyo
Model	MDF U76VC
Face Width (")	40
Door Swing Min. (")	3.5
Cubic Feet	25.7
2" Boxes	575
Boxes/Linear Foot	159

Table 1. Ultra Low Freezer dimensions and capacities.

Distributor	Sanyo
Manufacturer	Sanyo
Heat Exchangers	2
Water flow (lpm)	1
Water Delta T (°C)	14
Outer Door Hinge	3 ea barrel, 10 cm
Door Swing	120°
Outer Door	3" VIP
Latch	Cam, Manual
Gaskets	Door & Frame;
Inner Doors	Insulated with Gaskets
Vacuum Relief	Manual Knob Unheated, sealed
Noise	Quiet

Table 2. Freezer Construction and Doors. Water flow was measured when compressors were on. The Forma has very heavy duty hinges and gaskets mounted on cabinet that may be less likely to be scraped. The Sanyo has vacuum sealed walls that are thin and allow a lighter design overall.

Testing methods

Energy

We used Elite Pro energy meters on loan to UC Davis from the Pacific Gas and Electric Tool Lending Library, set up with 15 Amp current transducers (CT's). Split cord pigtails provided single conductors for CT placement, or CT's were placed over single conductors inside the mechanical cabinet. All three freezer amperages were measured simultaneously to obtain Volt-Amp values. Power factor was measured individually on each freezer by attaching voltage clips in a bare wire outlet box before energizing and then insulated, thus avoiding live connection hazards. We multiplied Volt-Amps by the power factors to calculate Watts during subsequent tests. Freezers were allowed to stabilize at each temperature for 6 –10 hours, then energy measurements were logged either at 1 minute or 5 minute intervals and averaged over at least 8 hours. Freezers were empty during all tests. Ambient temperature was 22 ± 0.3 °C.

Temperature

On the recommendation of cryo-temperature experts in the UC Davis Physics Department, we selected type J thermocouple (TC) wire for temperature sensing. We cut and welded 13 TC's at either 3 or 5 meters, and attached them to type J plugs. They were inter-calibrated for precision in a methanol bath with dry ice chunks and stirring. Three TC's were measured during both calibration sessions and averaged. Offsets from these averages were calculated for each TC and were applied to temperature readings, (Appendix B).

Up to eight TC's were logged simultaneously using an Omega TC-08 panel. Two TC's were placed in each ULF, one next to the installed temperature probe, and one in the geometric center of the cabinet, about 4 cm above the shelf. Intake air temperature was logged on the grill. Occasional room temperature measurements were made with an infrared thermometer, and room temperature was 21.4 ± 0.3 C.

Results

Temperature Characteristics

The purpose of this test was not detailed assessment of spatial and temporal uniformity. Some data was collected from the two TC's in the middle of the freezer and next to the sensor, (Table 3). The middle of the freezers were generally colder than at the sensors, which generally were near the bottom of the freezers. Further testing of temperature characteristics will be performed on loaded and unloaded air cooled freezers.

	Sanyo
Mean	-80.1
Max-Min	2.3
Measured - Set Point	-0.1
Sensor - Middle	1.3

Table 3. Temperature values over time and uniformity in the cabinet, (set point -80 degrees). All freezers had about the same characteristics, with the Forma having a slightly wider temporal variability and wider deviation from set point than the Dometic Freezer. Complete data available at -60 - -86°C in the appendix.

Energy Consumption

The Sanyo ULF consumed about 20 kWh/d at -80 °C, (Table 4). The energy intensity per box and cubic foot were also calculated .

	Sanyo
Energy Use kWh/d	20.1
Power Factor	0.97
Energy Intensity (W/CF)	32.6
Energy Intensity (W/Box)	1.46
Electricity Cost/y (8.5 c/kWh)	\$ 624
Electricity Cost/Box/y	\$ 1.08

Table 4. Energy consumption and intensity at the set point -80 °C.




Figure 1. Energy consumption of Sanyo ultra low, water cooled freezer at four set points. Water flow was about 1 lpm, which was lower than recommended. This apparently led to increase electricity consumption. A retest has been recommended.

Water Consumption

The intended coolant for these freezers is re-circulated district chilled water or water from a cooling tower, so water flow is not a major energy consideration under normal circumstances. The markedly lower (1/10) flow of the Sanyo ULF is striking, and enabled partially by having two heat exchangers. This could be a factor in emergency situations where process cooling pumping may be compromised. The very low Delta T and the lack of any difference in energy consumption when water flow was reduced by 75% indicates the Dometic and Thermo units need additional commissioning before installation.

Appendices.

A) Complete temperature measurements and deviations.

Mean Temperature measured at freezer sensor

-70	-68.0
-80	-79.9
-86	-84.0

Mean Temperature measured in middle of freezer

-70	-70.5
-80	-80.9
-86	-84.8

Sensor °C - Middle °C

-70	2.5
-80	1.1
-86	0.8

Temperature uniformity got better as set point decreased, a surprising result, and was about the same for Thermo and Dometic.


Temporal Range (Max-Min)

-70	3.8
-80	2.3
-86	3.7


Sensor °C -Set Pt

-70	2.0
-80	0.1
-86	2.0

- B) Thermocouple Precision measured in methanol and dry ice bath. The thermocouples were generally within 0.5 °C, though two were a degree or more from a mean of four TC's. Offsets were applied to each thermocouple's data.



- C) Sanyo Power profiles at -80 degrees Celsius



D) Example Sanyo power data at -80 degrees Celsius

Record	Record	Chan 3	Chan 3	Chan 3
Date	End Time	Avg. Volt	Avg. Amp	Avg. PF
9/8/2011	20:15:00	204.9	6.37	0.98
9/8/2011	20:20:00	206	0.29	0.96
9/8/2011	20:25:00	205.3	4.21	0.96
9/8/2011	20:30:00	204.9	7.14	0.98
9/8/2011	20:35:00	205.5	6.94	0.98
9/8/2011	20:40:00	205.6	6.81	0.98
9/8/2011	20:45:00	206.7	1.13	0.97
9/8/2011	20:50:00	206.7	1.96	0.94
9/8/2011	20:55:00	206	6.92	0.98
9/8/2011	21:00:00	206.2	6.98	0.98
9/8/2011	21:05:00	206.1	6.83	0.98
9/8/2011	21:10:00	206.9	1.2	0.97
9/8/2011	21:15:00	207	1.58	0.95
9/8/2011	21:20:00	206.3	6.52	0.97
9/8/2011	21:25:00	206.4	6.98	0.98
9/8/2011	21:30:00	206.8	6.84	0.98
9/8/2011	21:35:00	207.3	0.55	0.97
9/8/2011	21:40:00	207.2	1.7	0.94
9/8/2011	21:45:00	206.5	6.63	0.97
9/8/2011	21:50:00	206.3	6.97	0.98
9/8/2011	21:55:00	206.5	5.97	0.98
9/8/2011	22:00:00	206.8	0.29	0.96
9/8/2011	22:05:00	205.8	2.18	0.94
9/8/2011	22:10:00	205.1	7.18	0.98
9/8/2011	22:15:00	205.3	6.92	0.98
9/8/2011	22:20:00	205.7	4.78	0.98
9/8/2011	22:25:00	206.3	0.29	0.96
9/8/2011	22:30:00	206	2.42	0.94
9/8/2011	22:35:00	205.1	7.19	0.98
9/8/2011	22:40:00	204.9	6.92	0.98
9/8/2011	22:45:00	205.2	4.44	0.98
9/8/2011	22:50:00	205.9	0.29	0.96
9/8/2011	22:55:00	206	2.33	0.94
9/8/2011	23:00:00	205.9	7.19	0.98
9/8/2011	23:05:00	206	6.92	0.98
9/8/2011	23:10:00	206.6	3.54	0.98
9/8/2011	23:15:00	207.4	0.29	0.96